

Typical one and two family residences permitted between 1975 and August 27, 1997:

Prior to the arrival of the fire department:

- Make sure that your posted street number is visible from the street (MGL c.148 § 59)
- Make sure that you have the proper type of detectors and that they are less than 10 years old, the fire inspector may take down detectors for compliance verification.
- Make sure that all detectors are installed in the proper locations.
- Make sure that all detectors are working properly.

Smoke detectors are required as follows:

- Must be hardwired interconnected smoke detectors.
- One smoke detector on every habitable level of the residence.
- One smoke detector on the ceiling at the base of each stairway, but not within the stairway.
- One smoke detector on the ceiling outside of each separate sleeping area.
- A minimum of one smoke detector must be installed for every 1,200 square feet of living space, per level.

Carbon monoxide alarms are required as follows:

- On every level of the residence, including habitable portions of basements and attics and must be located within 10 feet of each bedroom door.
- Combination detectors (photoelectric smoke and carbon monoxide detector) may be used anywhere.
- Combination detectors (ionization smoke and carbon monoxide detector) may be used if the detector is outside of 20 feet of a kitchen or bathroom (containing a bathtub or shower).
- May be either: battery powered, plug-in with battery backup, hardwired with battery backup, or system type.
- Follow the manufacturer's instructions for placement.