

Typical one- and two-family residences permitted on or after January 1, 2008:

Prior to the arrival of the fire department:

- Make sure that your posted street number is visible from the street (MGL c.148 § 59)
- Make sure that you have the proper type of detectors and that they are less than 10 years old, the fire inspector may take down detectors for compliance verification.
- Make sure that all detectors are installed in the proper locations.
- Make sure that all detectors are working properly.

Smoke detectors are required as follows:

- One smoke detector on every habitable level of the residence.
- One smoke detector on the ceiling at the base of each stairway, but not within the stairway.
- One smoke detector on the ceiling outside of each separate sleeping area.
- One smoke detector on the ceiling inside every bedroom.
- A minimum of one smoke detector must be installed for every 1,200 square feet of living space per level.
- Must be hardwired and interconnected smoke detectors with battery backup.
- If the smoke detector is within 20 feet of a kitchen or bathroom (containing a bathtub or shower), the smoke detector is required to be a photoelectric detector.
- If the smoke detector is outside of 20 feet of a kitchen or a bathroom (containing a bathtub or shower), the smoke detector is required to be either a photoelectric detector or a dual detector (containing both ionization and photoelectric technologies).

Carbon monoxide alarms are required as follows:

- On every level of the residence, including habitable portions of basements and attics and located within 10 feet of each bedroom door.
- Combination detectors (photoelectric smoke and carbon monoxide detector) may be used.
- **Must be hardwired and interconnected with battery backup.** (May be separately wired from the existing smoke detection system.)
- Follow the manufacturer's instructions for placement.

Heat detectors are required as follows:

- Must have a single heat detector in any garage attached to or under the residence.
- Must be hardwired and interconnected with or without battery backup to the existing smoke detection system.
- Heat detectors are not required in older homes unless renovation, addition or modification occurs after Jan. 1, 2008.